

MOROCCO WATER DEPARTMENT

Public Water Supply ID: IN5256006
Consumer Confidence Report Addendum

Definitions:

LRAA: Locational Running Annual Average

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

Required Monitoring Data:

Total Coliform				
Microbiological	Result	MCL	MCLG	Typical Source
Coliform TCR	In the month of June, 2 samples returned as positive	Treatment Technique Trigger	0	Naturally present in the environment

Disinfection Byproducts								
Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
Total Haloacetic Acids	1340 E MI AVE	2023-2024	27	6.4-14	Ppb	60	0	By-product of drinking water disinfection
Total Haloacetic Acids	409 W MI AVE	2023-2024	29	22-38	Ppb	60	0	By-product of drinking water disinfection
TTHM	1340 E MI AVE	2023-2024	68	51-76	Ppb	80	0	By-product of drinking water disinfection
TTHM	409 W MI AVE	2023-2024	65	41-79	Ppb	80	0	By-product of drinking water disinfection

Violations:

MOROCCO WATER DEPARTMENT

Public Water Supply ID: IN5256006
Consumer Confidence Report Addendum

Violation Period	Analyte	Violation Type	Violation Explanation
4/30/2024- 5/30/2024	E.Coli	Report Sample Result/Fail Monitor RTCR	Lab failed to send reports to the state
9/30/2024- 12/30/2024	Radium-228	9/30/2024- 12/30/2024	Lab failed to send reports to the state
9/30/2024- 12/30/2024	Radium-226	9/30/2024- 12/30/2024	Lab failed to send reports to the state
9/30/2024- 12/30/2024	Gross Alpha, EXCL. Radon & U	9/30/2024- 12/30/2024	Lab failed to send reports to the state

We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessments to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct a Level 1 assessment. 1 Level 1 assessment was completed. In addition, we were required to take 0 corrective actions and we completed 0 of these actions.